

**CITY OF SCOTTSVILLE
FIRE INSPECTION CHECK
FOR
FIREWORKS SALES**

Location: _____

Name: _____

Type: Tent / Building (circle one)

_____ Fire extinguishers every 75' (at least (1) class 2A and (1) pressurized water type)

_____ No Smoking sign 4" letters against a contrasting background. No smoking
Within 50 ft. of tent.

_____ The tent must be no more than 150' from public way for the fire trucks to
Service the area.

_____ Tents more than 800 sf are to be treated as a building.

_____ Tents are to be 300' from gas stations or LP stations.

_____ 48" isles no dead-end isles.

_____ No fireworks discharged within 300 ft. of the tent.

_____ Exits signage and EM lights are not required if the tent is not open after
dusk, but they are, if open after dusk.

_____ Exit openings 44" wide minimum.

_____ Portable generators 20 ft. from the tent, fuel 20 ft. from the tent.

_____ Cooking equipment 20ft. from the tent.

_____ Open flame cooking 50' from the tent.

Date: _____ Time: _____

Print: Jerry Biddle

Sign: _____

Code Enforcement Officer (Designee of Fire Chief)